

交大室內空氣品質自主量測成果表

巡查檢驗人員：馮慧敏 巡檢區域：交大圖書館 日期：103.8.20

(一)巡查檢驗結果						
項目 巡檢點	二氧化碳 (CO ₂)			甲醛 (HCHO)		
	1.開始 時間	2.結束 時間	3.檢測濃度值 (ppm)	1.開始 時間	2.結束 時間	3.檢測濃度值 (ppm)
2F-1	9:00	9:01	600	9:00	9:01	0
2F-2	9:05	9:06	598	9:05	9:06	0
2F-3	9:08	9:09	607	9:08	9:09	0
2F-4	9:10	9:11	540	9:10	9:11	0
2F-5	9:12	9:13	510	9:12	9:13	0
2F-6	9:15	9:16	612	9:15	9:16	0
3F-1	9:25	9:26	658	9:25	9:26	0
3F-2	9:27	9:28	607	9:27	9:28	0
3F-3	9:30	9:31	612	9:30	9:31	0
3F-4	9:32	9:33	636	9:32	9:33	0
3F-5	9:34	9:35	622	9:34	9:35	0
3F-6	9:36	9:37	673	9:36	9:37	0
4F-1	9:40	9:41	578	9:40	9:41	0
4F-2	9:42	9:43	564	9:42	9:43	0
4F-3	9:43	9:44	531	9:43	9:44	0
4F-4	9:45	9:46	521	9:45	9:46	0
4F-5	9:46	9:47	533	9:46	9:47	0
4F-6	9:49	9:50	527	9:49	9:50	0
5F-1	9:55	9:56	593	9:55	9:56	0
5F-2	9:57	9:58	571	9:57	9:58	0
5F-3	9:59	10:00	569	9:59	10:00	0
5F-4	10:02	10:03	588	10:02	10:03	0

5F-5	10:04	10:05	548	10:04	10:05	0
5F-6	10:06	10:07	597	10:06	10:07	0
6F-1	10:10	10:11	548	10:10	10:11	0
6F-2	10:12	10:13	555	10:12	10:13	0
6F-3	10:14	10:15	567	10:14	10:15	0
6F-4	10:16	10:17	541	10:16	10:17	0
6F-5	10:18	10:19	539	10:18	10:19	0
6F-6	10:20	10:21	547	10:20	10:21	0
7F-1	10:24	10:25	567	10:24	10:25	0
7F-2	10:26	10:27	602	10:26	10:27	0
7F-3	10:28	10:29	639	10:28	10:29	0
7F-4	10:31	10:32	557	10:31	10:32	0
7F-5	10:33	10:34	543	10:33	10:34	0
7F-6	10:35	10:36	569	10:35	10:36	0

(二)檢測儀器基本資料

1.檢測項目	2.檢測儀器廠牌/型號/序號	3.偵測範圍	4.儀器原理	5.校正日期
二氧化碳(CO ₂)	YES-AIR-D	0~5000ppm	紅外線	2013.10.9
甲醛(HCHO)	YES-AIR-D	0~10ppm	電化學	2013.10.9